

# Confirmation

## BREEAM<sup>®</sup> NOR 2016

On 29 April 2020, Eurofins Product Testing A/S received a sample of joint sealant with the product name:

### Sponplatelim Hybrid

supplied by

### Essve Produkter AB

The sample was supplied as being representative of the manufactured product, and it has been tested in accordance with the relevant ISO 16000-3 -6 -9 -11 and EN 16516 in the latest versions (See test report no. 392-2020-00187701\_I\_EN).

**The test results of the tested joint sealant indicate that the product qualifies for BREEAM-NOR New Construction 2016 v1.1 specifications on VOC emissions complying with:**


**BREEAM NOR 2016 requirements on "Volatile Organic Compounds" in Hea 02 criteria:**

- TVOC was below the limit of 60 µg/m<sup>3</sup> after 28 days
- Formaldehyde was below the limit of 10 µg/m<sup>3</sup> after 28 days
- Carcinogenic substances was below the limit of 1 µg/m<sup>3</sup> after 28 days

18 June 2020



Malene Laugesen  
Analytical Service Manager



Rasmus Stengaard Christensen  
Analytical Service Manager, MSc in Chemistry