

TEST CERTIFICATE

ST-23-05-22-03

Products: DPL-laminate floor covering
Thickness 6 mm - 14 mm

Producer: Kronospan GmbH Lampertswalde
Mühlbacher Straße 1
01561 Lampertswalde

Order: Determination of the light fastness according to EN 13329:2016+A2:2021-09

Test Report: 2117133/2022/3/W/1


Test Result:

Property	Results	Evaluation according to EN 13329:2016+A2:2021-09, Table 1
Light fastness according to EN 13329:2016+A1:2017-10 Annex E	Grey scale value 4 - 5	General requirements according to Table 1 are fulfilled

Dresden, 22/05/2023



Head of laboratory

Engineer in charge